

UPPER FREDERICK TOWNSHIP

P.O. Box 597, Frederick, PA 19435

TOWNSHIP BUILDING
3205 Big Road, Obelisk, PA 19492

TELEPHONE-610-754-6436
FAX-610-754-6828

CHECK LIST FOR RESIDENTIAL USES & RESIDENTIAL ACCESSORY STRUCTURES

- _____ Permits for Accessory Structures
 - _____ Swimming Pool - 4 Foot Fence
 - _____ Roof/Cellar/Perimeter/Sump Pump Not Connected To Sewer
 - _____ Smoke Detector Each Level
 - _____ Fire Extinguisher 2 1/2 lb. BC Dry Powder Minimum
 - _____ 60 Amp. Service or 3 Wire 100 Amps.
 - _____ For Kitchens, Bathrooms and Water Services Receptacles within 6 feet must Be GFI
 - _____ Gas Ranges Must Have A Shut-Off Valve
 - _____ Electric Ranges Must Be Connected To Outlets - Not Hard-Wired
 - _____ Street Numbers Must Be Visible (3" Minimum Numerals)
 - _____ Clean, Safe and Sanitary
 - _____ Heating Unit Must Be Inspected By an Authorized Service Contractor
 - _____ All fuel-burning appliances, fireplaces and chimneys/vents must be inspected and certified safe to operate by an authorized service contractor.
 - _____ Alarm System Must Be Registered With the Township
 - _____ Applications for A Water/Sewer Certification Are Required For Perkiomen Crossing and Ivy Ridge Development, Must Be Filed With The Township
 - _____ Has the septic tank been pumped within the last 3 years? Please provide receipt.
-

